

SUMMARY PAGE

Name of Facility: City of Donalsonville - H M Shingler WPCP

NPDES Permit No.: GA0026123

This is a reissuance of the NPDES permit for the H M Shingler WPCP. Up to 1.0 MGD (monthly average) of treated domestic wastewater is discharged to Fish Pond Drain in the Flint River Basin. The permit expired on August 31, 2021 and the facility is operating under a Consent Order.

The permit was placed on public notice from XXXX to XXXXX.

Please Note The Following Changes to the Proposed NPDES Permit From The Existing Permit:

Part I.B.1 – Effluent Limitations and Monitoring Requirements:

- Removed long term biochemical oxygen demand test as was conducted and completed in current permit.
- Removed 4,4-DDT, Dieldrin, and Heptachlor monitoring in accordance with EPD's reasonable potential procedures.
- Added thallium, copper, zinc, and mercury effluent monitoring and total hardness stream monitoring in accordance with EPD's reasonable potential procedures.

Part I.B.2 – Instream Surface Water Quality Monitoring:

- Decreased sampling frequency from weekly to monthly and revised monitoring period from May to November to May to October.

Part I.D.2. – Reporting Requirements

- Updated to the new e-Reporting Phase II compliance date of December 21, 2025, per 40 CFR 127.16. The revision to the rule became effective January 4, 2021.

Standard Conditions and Boilerplate Modifications:

The permit boilerplate includes modified language or added language consistent with current NPDES permits.

Final Permit Determinations and Public Comments:

- Final issued permit did not change from the draft permit placed on public notice.
- Public comments were received during public notice period.
- Public hearing was held on
- Final permit includes changes from the draft permit placed on public notice. See attached permit revisions and/or permit fact sheet revisions.